

IC-Meter data:

Monthly Statistics for Energy and Indoor Climate

August 2015

Location: Demo 1: Energy and Water

Room: Green Tech House Vejle

Box ID: 75C0EACC

User: For batch operations Administrator <admin@ic-meter.com>

Location created: 25th Mar 2015

Timezone: Europe/Copenhagen

Energy Balance for the Entire Building

1 3 5 7 9



Central heat actual indoor temp. 1,207 kWh

1 3 5 7 9



Savings if 20 °C indoor 926 kWh (77%)



Passive solar: 548 kWh



Specific heat losses: 465 W/°C

Energy label and yearly consumption



Energy label: A 2020 (Calculated after BE10 - Denmark)



Energy Supply: 42,183 kWh/year (11 kWh/m²*year)

- Measured data calibrated to 20 °C indoor and standard DK-Weather conditions

Indoor Climate Meter data - Avg. Values for 6 active hours*

*On workdays between 8:00-14:00



CO₂: 474 ppm



Temperature: 24.0 °C






Relative humidity: 51.1 %




More Statistics >>>

Relative distribution for time of the day in workdays and weekends, ventilation key figures and local weather


Classification of indoor climate

All indoor meter data are classified according to a Smiley/traffic light concept, where  green is good,  yellow is less good and  red is bad.

The classification reflects the indoor climate with respect to health, what is good for the building and the climate outside. The thresholds as listed in the table below have been specified by the Technological University of Denmark, Center for Indoor Climate and Energy.




Indoor climate classes	Bad	Less good	Good	Less good	Bad
					
Fresh Air (CO ₂) ppm			Below 800	800-1,000	Above 1,000
Temperature °C	Below 18.2	18.2-20.2	20.2-23.2	23.2-25.2	Above 25.2
Relative Humidity %	Below 20	20-25	25-48.5	48.5-60.7	Above 60.7

CO₂ - August 2015




CO₂ - Workdays

Relative distribution on the three climate classes for the period




Average CO ₂	Good	Less good	Bad
448 ppm	 100 %	 0 %	 0 %

Relative distribution for time of the day and climate classes




CO₂ - Weekends


Relative distribution on the three climate classes for the period

Average CO ₂	Good	Less good	Bad
439 ppm	 100 %	 0 %	 0 %

Relative distribution for time of the day and climate classes






Temperature - August 2015




Temperature - Workdays

Relative distribution on the three climate classes for the period




Average Temperature	Good	Less good	Bad
24.0 °C	 17 %	 71 %	 12 %

Relative distribution for time of the day and climate classes




Temperature - Weekends


Relative distribution on the three climate classes for the period

Average Temperature	Good	Less good	Bad
25.1 °C	 5 %	 63 %	 32 %

Relative distribution for time of the day and climate classes






Humidity - August 2015




Humidity - Workdays

Relative distribution on the three climate classes for the period




Average Humidity	Good	Less good	Bad
49.5 %	 43 %	 54 %	 3 %

Relative distribution for time of the day and climate classes




Humidity - Weekends

Relative distribution on the three climate classes for the period

Average Humidity	Good	Less good	Bad
45.6 %	 63 %	 31 %	 6 %

Relative distribution for time of the day and climate classes



Period: August 2015

Ventilation key figures

Air change rate: 0.9 /h

2,750.3 m³/h

Heavy ventilation: N/A minutes /day

Vapor production: 1.3 kg /day

IC-Meter calculates four key figures based on measurements from the previous 30 days.

- *Relative air change per hour pct./hour* (Air change rate) indicates how many m³ get replaced in a room during an hour, compared to the volume of the room.
- *Absolute air change per hour m³/hour* indicates how many m³ get replaced in a room during an hour.
- *Heavy ventilation minutes/day* indicates minutes when the relative air change rate is above 3. This corresponds to e.g. two open windows resulting in the air in the room being replaced quickly.
- *Vapor production kg/day* indicates the average total vapor produced in a room to maintain a higher absolute humidity indoor than in the air outside.

More information

More information on www.ic-meter.com

Period: August 2015

Local Weather

Average temperature	Min	Max
17.5 °C	7.3 °C	27.7 °C

Average humidity	Min	Max
73.6 %	30.8 %	98.8 %

Wind speed m/s	Direction		
Average wind speed	1.	2.	3.
2.3 m/s	E	SE	SV

Read more about the measurement concept of IC-Meter on www.ic-meter.com